

# CERTIFICATE

## 0960-CPR-SKGIKOB.011673.01.ENG

Issued: 13-11-2019  
Valid until: 13-11-2024



### Certificate holder

Lieftink Geveltechniek  
Produktieweg 17  
2404 CC Alphen aan de Rijn  
T: +31 (0)172 469 670  
E: info@lieftink.nl  
I: www.lieftink.nl

## Certificate of constancy of performance

### Declaration of SKG-IKOB (Notified Body 0960)

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### FIRE RESISTING AND/OR SMOKE CONTROL DOORSETS AND/OR OPENABLE WINDOWS COVERED BY EN 14351-1

as specified in the attached appendix placed on the market under the name or trade mark of the holder of this certificate and produced by the holder of this certificate or for the holder of this certificate in the manufacturing plant(s) if mentioned above.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

### EN 16034:2014

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued on 13 November 2019 and will remain valid until the date as mentioned at this certificate as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

For SKG-IKOB

A blue ink handwritten signature, appearing to be 'H.A.J. van Dartel', written over a light blue circular stamp or seal.

ir. H.A.J. van Dartel  
Certification manager

The users of this certificate are advised to verify at [www.skgikob.nl](http://www.skgikob.nl) if this certificate is still valid and actual.  
This certificate consists of 2 pages.



SKG-IKOB Certificatie  
Poppenbouwing 56  
4191 NZ Geldermalsen

Postbus 202  
4190 CE Geldermalsen

T 088-2440100  
info@skgikob.nl  
www.skgikob.nl

CERTIFICATE

# CERTIFICATE

Lieftink Geveltechniek

Number: 0960-CPR-SKGIKOB.011673.01.ENG

Page 2 of 2

## Appendix 1

### CERTIFICATE OF CONSTANCY OF PERFORMANCE

	Specification	Levels and classes of performance
1	<p><b>System:</b> AWS 60 FR30</p> <p><b>Material:</b> Aluminium</p> <p><b>Intended use:</b> Intended to be used in fire and/or smoke compartmentation and/or escape routes</p>	EI <sub>1</sub> 30, EI <sub>2</sub> 30
2	<p><b>System:</b> AWS 70 FR30</p> <p><b>Material:</b> Aluminium</p> <p><b>Intended use:</b> Intended to be used in fire and/or smoke compartmentation and/or escape routes</p>	EI <sub>1</sub> 30, EI <sub>2</sub> 30
3	<p><b>System:</b> ADS 80 FR30</p> <p><b>Material:</b> Aluminium</p> <p><b>Intended use:</b> Intended to be used in fire and/or smoke compartmentation and/or escape routes</p>	EI <sub>2</sub> 30